



HEAVY ENGINEERING CORPORATION LIMITED
(FIRE SERVICE/FFP)
DHURWA, RANCHI - 834004

No. FF/Fire/2023- 50

Date: 09/08/2023

Subject: Inspection Review of Fire Fighting system installed in Saraswati Shishu Vidya Mandir, School, Dhurwa Ranchi.

Ref :- Letter No- SVMS/2023-24/466, Dated: 17.07.2023.

With reference to the above subject, Fire Fighting system has been installed in Saraswati Shishu Vidya Mandir School, Dhurwa Ranchi, Where the Assistant Manager, I/C/(Fire)/FFP/HEC visit to the school premises for inspection on dated- 25.07.2023.

During inspection of said school premises and observed the school conforms the guidelines of National Building Code (Part-4, Fire and Life Safety). The total building area in respect of aforesaid school is 41012 sq. feet with 65 different types of rooms such as classroom, offices, practical room etc and the total number rooms in the of Hostel is 34.

In said school premises following Fire Fighting system were found adequate and working condition.

1.	ABC Type Extinguisher, 06 kg Capacity	43 Pcs
2.	ABC Type Extinguisher, 04 kg Capacity	08 Pcs
3.	Co ₂ Type Extinguisher, 06 kg Capacity	02 Pcs
4.	Hose Reel	07 Pcs
5.	Pillar Hydrant	08 Pcs
6.	Hose Box	08 Pcs
7.	Hose Box	17 Pcs
8.	Over Head Tank	10,000 litters

All the installed firefighting equipment's are maintained in working order and the validity Period of the fire extinguisher from 20.07.2023 to 20.07.2024 in accordance with rule and subject to Compliance of the conditions.

Yours faithfully,

Ravindra Kumar
09/08/23.

(Ravindra Kumar)

Asstt. Manager(I/C)Fire/FFP

P. No: 89024

Ravindra Kumar
Asst. Manager (Fire)
F.F.P., H.E.C. Ltd.
Ranchi-4

MANAGER
Saraswati Shishu Vidya Mandir
Dhurwa, Ranchi-834004

जलन कुमार
Principal

Saraswati Shishu Vidya Mandir +2
CBSE AFF No.-3430123, School No.-66320
Dhurwa, Ranchi-834004 (Jharkhand)